

CERTIFICATE OF COMPLIANCE

Certificate Number EX28626
Report Reference EX28626-20210924
Date 2022-June-10

Issued to: The African Company For Trading And Engineering
Plot no. 132 - 6th Industrial Zone Extension
6th october city EG

This is to certify that
representative samples of

HANGERS, PIPE
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: ANSI/CAN/UL 203 - Standard for Pipe Hanger Equipment
for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any investigation and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at ULCustomerService@ul.com

